

Certificate of Compliance

Certificate Number: LR 12730-384
KEMA Ref. 97.3664

Revision: LR 12730-384


Date Issued: September 24, 1997

Issued To: Siemens AG
Abt. ASI 2 GWA TPA
Werner von Siemens
Strasse 48
92220 AMBERG
Germany

The products listed below are eligible to bear the CSA Mark.

Issued By: J. Pankowski
CSA Montreal

Signature



PRODUCTS

- Shunt Release, open type, Series 3RV19, operating voltage 415 Vac max, 240 Vdc max
- Undervoltage Tripping Units, open type, Series 3RV19, operating voltage 300 Vac max, 240 Vdc max

Notes:

- 1 Series 3RV19 shunt release and undervoltage trip release for use with this manufacturer's devices Series 3RV1.
- 2 Certified for use in equipment where the acceptability of the combination is to be determined by the Canadian Standards Association.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 0 - M91 - General Requirements
" " " " 14 - 95 - Industrial Control Equipment