

Certificate of Compliance

Certificate: 1314466

Master Contract: 159134 (LR 28828)

Project: 1314466


Date Issued: October 25, 2002

Issued to: Siemens Milltronics Process Instruments Inc.
1954 Technology Dr.
Peterborough, ON K9J 7B1
CANADA
Attention: Mr. T J Adams

The products listed below are eligible to bear the CSA Mark shown



Issued by: P. Schimmoeller



Authorized by: George Gruss
Operations Manager

PRODUCTS

CLASS 2258-03 PROCESS CONTROL EQUIPMENT - Intrinsically Safe and Non Incendive Systems - For Hazardous Locations

Class I, Division 1, Groups A, B, C and D; T6 at max ambient 40°C

Intrinsically Safe Programmer Version A and B; battery operated using 3V Lithium Battery; T6 max ambient = 40°C



CSA INTERNATIONAL

Certificate: 1314466
Project: 1314466

Master Contract: 159134
Date: October 25, 2002

APPLICABLE REQUIREMENTS

C22.2 No. 157-92 - Intrinsically Safe and Non-incendive Electrical Equipment for Use in Hazardous Locations
CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures
CSA Std C22.2 No 213-M1987 Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations
CSA Std C22.2 No. 142-M1987 - Process Control Equipment

MARKINGS

- CSA Monogram;
- Company Name;
- Model Number;
- Serial Number;
- Electrical rating;
- Hazardous Location designation;