

# CERTIFICATE

issued by

**Rittal GmbH & Co. KG**

Auf dem Stützelberg  
D-35745 Herborn

Quality Management

Hereby we confirm that the Rittal enclosure SE8

5830.500	5831.500	5832.500
5833.500	5834.500	5840.500
5841.500	5843.500	5844.500
5845.500	5842.500	5846.500

complies with the requirements of the tests of UL 508A rated Type 12 (NEMA12) and fulfil the protection category IP55 according to EN 60529 "Degrees of protection provided by enclosures" dated September 2014.

Herborn, 2014-12-03

  
Axel R Emmert  
Quality Management Laboratory



Rittal's test laboratory is accredited with the German Accreditation Council (DAkks) No. D-PL-17086-01-01 and Underwriters Laboratories Inc.

Rittal GmbH & Co. KG  
Personally liable:  
Rittal Management GmbH,  
Schwende

Management:  
Friedhelm Loh (President)  
Karl Christoph Caselitz  
Dr. Guido Stannek  
Dr. Thomas Steffen  
Hermann Tetzner  
Michael Weiher

Rittal GmbH & Co. KG  
Auf dem Stützelberg  
D-35745 Herborn  
Phone: +49(0)27 72 5 05-0  
Fax: +49(0)27 72 5 05-23 19  
E-Mail: info@rittal.de  
www.rittal.de  
HRA 6126 Wetzlar

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES

