



Product Registration Certificate

Printed on: 01 May 2014

Registration No. 2493
Title OS Switch Fuses
Status Authorised For Use
Supersedes ProductID N/A
Superseded By ProductID N/A
Date Authorised for Use 24 Apr 2014
Primary Use Isolation and disconnection with fuse protection of low voltage loads
Additional Info/KeyWords 3&4 pole 20 to 1250amp at 690v. Full range of accessories available and manufactured to IEC-60947-1 & 3. Manufacturer: ABB Limited, Tower Court, Foleshill Enterprise Park, Courtaulds Way, Coventry. CV6 5NX. T:024 7636 8500.
Classification Hierarchy Electrical
 Stn Lighting & Pwr AC Only
 LUL Supplied-Local Distrbtn | LUL Supplied-Local Distrbtn
Manufactured By ABB Ltd

Requirements

ReqID	Requirement	Status	Trial
No records to display.			

Conditions

Description	Linked To ReqID
These products are compliant for installations in surface locations and within one hour fire rated room of volume less than 75m ³ with a fire detection and alarm system in sub-surface locations, as specified in LU standard 1-085.	

Evidence

EvidenceText	EvidenceType	FileName	Linked To ReqID
Product Catalogue	User Guide	1scc311013c0201 OS Catalogue 2014(2493).pdf	

Reminder: Products must not be publicised as being authorised for use by London Underground Limited (LUL) without also stating any conditions or limitations that apply, nor may any LUL intellectual property rights (such as the roundel trademark) be used in any such publicity. LUL reserves the right to withdraw authorisation of any product publicised in breach of this reminder. Refer to Web site www.lu-apr.co.uk to check current status, download attachments and for details of other products.

MAYOR OF LONDON